TEST & INSPECTION CERTIFICATE

MAKER BY：ELITE LINE INDUSTRIAL CORPORATION
APPR CLASS：ISO-9001
REPORT NO：E201806200003-MY

DATE OF ISSUE：13, July. 2018

Product：Direct-Activated Pressure Reducing Valve

Fluid：Steam

ITEM No	SIZE	Q'TY	BODY MATERIAL	CONNECT TYPE	REMARK
RET-15-S	1/2"- BSPT	24pcs	Stainless Steel #CF8M	Thread Type	ZT-105339~ZT-105362
RET-25-S	1"- BSPT	12pcs	Stainless Steel #CF8M	Thread Type	ZT-105363~ZT-105374
RET-40-S	1-1/2"- BSPT	2pcs	Stainless Steel #CF8M	Thread Type	ZT-105375~ZT-105376

PRESSURE TEST			OPERATION TEST	DIMENSION/INSPECTION
BODY	21 Kg/cm^2	OK	GOOD	GOOD
SEAT	16 Kg/cm^2	OK	GOOD	GOOD

ADJUSTMENT RANGE			
ADJUSTMENT RANGE (OUTLET RESSURE)	SPRING RANGE #1	4 ~ 10 kgf/cm^2	OK

NOTE:

OTHER:

Q.A CHECK BY: 吳 忠

Q.A MANAGER: 汪孟樺