

TEST & INSPECTION CERTIFICATE

MAKER BY : ELITE LINE INDUSTRIAL CORPORATION

APPR CLASS : ISO-9001

REPORT NO : E201901280002-MY

DATE OF ISSUE : 19. Feb. 2019

Product : Direct-Activated Pressure Reducing Valve

Fluid : Steam (100℃ ~150℃)

ITEM No	SIZE	Q'TY	BODY MATERIAL	CONNECT TYPE	REMARK
RET-20-S	3/4"-BSPT	30pcs	Stainless Steel #CF8M	Thread Type	ZT-111128~ZT-111157
RET-25-S	1"-BSPT	8pcs	Stainless Steel #CF8M	Thread Type	ZT-111158~ZT-111165
RET-40-S	1½"-BSPT	8pcs	Stainless Steel #CF8M	Thread Type	ZT-111166~ZT-111173
RET-50-S	2"-BSPT	10pcs	Stainless Steel #CF8M	Thread Type	ZT-111174~ZT-111183
PRESSURE TEST			OPERATION TEST	DIMENSION/INSPECTION	
BODY	21 Kg/cm ²	OK	GOOD	GOOD	
SEAT	16 Kg/cm ²	OK	GOOD	GOOD	
ADJUSTMENT RANGE					
ADJUSTMENT RANGE (OUTLET RESSURE)			SPRING RANGE #1	4 ~ 10 kgf/cm ²	OK
NOTE:			OTHER:		

Q.A CHECK BY:

吳 忠

Q.A MANAGER:

汪孟樺